




# W 8046 M6

Maintenance Instruction

## Lubricating oil pump



© INNIO Jenbacher GmbH & Co OG  
Achenseestr. 1-3  
A-6200 Jenbach, Austria  
[www.innio.com](http://www.innio.com)



1	Scope .....	1
2	Purpose.....	1
3	Maintenance interval.....	1
4	Safety information.....	2
5	Additional information.....	2
6	Work steps.....	2
6.1	Changing the lubricating pump .....	2
6.2	Replacing O-rings .....	2
7	Revision code.....	3

---

**The target recipients of this document are:**

Customers, distribution partners, service partners, commissioning partners, subsidiaries/branches, Jenbach location

---

**INNIO proprietary information: CONFIDENTIAL**

The information contained in this document is the proprietary information of INNIO Jenbacher GmbH & Co OG and its subsidiaries and is disclosed in confidence. It is the property of INNIO and shall not be used, disclosed to others or reproduced without express written consent. This includes but is not limited to use for the creation, manufacture, development or derivation of any repairs, modifications, spare parts, designs or configuration changes, or for obtaining government or regulatory approval to do so. If consent is given for reproduction in whole or in part, this notice and the notice set forth on each page of this document shall appear in any such reproduction in whole or in part.

---

**UNCONTROLLED WHEN PRINTED OR TRANSMITTED ELECTRONICALLY**


---

## 1 Scope

This Maintenance Instruction (W) applies to the following Jenbacher Gas Engines:

- Type 6 engines

## 2 Purpose

This Maintenance Instruction (W) describes the maintenance interval.

## 3 Maintenance interval

Maintenance work	Maintenance interval	Carried out by <sup>*)</sup>
⇒ Replacing O-rings	20,000 Oh / 5 years	INNIO
⇒ Changing the lubricating pump	30,000 Oh	INNIO

**Valid for:**

- Type 6: Maintenance schedule A Maintenance schedule B Maintenance schedule D

**\*) Carried out by This column defines who carries out the maintenance work.**

K	This activity is to be carried out by the customer, INNIO or a company selected and authorised by INNIO to carry out this work.
INNIO	This activity is to be carried out by INNIO or a company selected by INNIO authorised to carry out this work.

## 4 Safety information

### ⚠ WARNING



#### Danger from unauthorised restarting

Serious injuries such as cutting, crushing, severing or shearing of body parts due to unintentional contact with rotating or moving machine parts.

- Shut down the engine as described in TA 1100-0105.
- Secure the engine against unauthorised restarting in accordance with TA 2300-0010.



### ⚠ WARNING



#### Personal injury

Failure to use personal protective equipment and comply with safety instructions or employee protection information may lead to personal injury.

- Wear the relevant personal protective equipment (PPE).
- Observe the safety instructions as per TA 2300-0005.
- Observe the employee protection information as per TA 2300-0001.

## 5 Additional information

### Relevant documents:

TA 1100-0105 – Engine shut-down

TA 2300-0001 – Employee protection

TA 2300-0005 – Safety instruction

TA 2300-0010 – Guidelines for using the LOTO kit

## 6 Work steps

### 6.1 Changing the lubricating pump

This activity is to be carried out by INNIO or a company selected by INNIO authorised to carry out this work.

### 6.2 Replacing O-rings

This activity is to be carried out by INNIO or a company selected by INNIO authorised to carry out this work.

## 7 Revision code

## Revision history

Index	Date	Description / Revision summary	Expert Auditor
5	15.03.2019	Korrektur Wartungsintervall „Schmierölpumpe tauschen“ / Correction maintenance intervall „Replace Oilpump“	<b>Wiechenthaler S.</b> <i>Robert P.</i>
4	28.02.2019	Strukturelle Anpassungen / Structural adaption Arbeitsschritte „Schmierölpumpe tauschen“ und "O-Ringe tauschen“ ergänzt / work steps „Replace Oilpump“ and "Replacing O-rings“ added	<b>Leroux .</b> <i>Madl W.</i>
3	09.08.2012	NEU: Einstellung des Druckes / new: Regulation of the pressure	<b>Bilek</b> <i>Feyersinger</i>
2	10.06.2010	Anpassung Schutzvermerk / Adjustment classification	<b>Schartner</b> <i>Schartner</i>
1	26.05.2010	Umstellung auf CMS / Change to <b>C</b> ontent <b>M</b> anagement <b>S</b> ystem ersetzt / replaced Index: <b>b</b>	<b>Provin</b> <i>Licht</i>

