

Distribution:	010-03 VSD	No.
GEJ-Service	29.04.03	Date
Subsidiaries-Service	rev. 20.02.04	
Service Partner	GE Jenbacher VSD H. Sonnerer tel 2168 - fax 42168	From

Costumers' partizipation in cylinder head replacement due to premature valve regression - Type 6 E

The following serves to inform you on the expected cylinder head service lives and the regulation involved.


In case that a cylinder head of **Type 6E engines** needs to be replaced, GE Jenbacher offers a regulation for cost sharing GE Jenbacher – customer. This regulation may only be used on cylinder heads of type 6E with premature valve regression.

Prerequisite is the adherence to the maintenance instructions and the peripheral conditions according to TI 1100-0110. Additionally an appropriate and continuous documentation of the valve regression must have been given to Jenbach.

The operating hours at the time of valve regression measurement are used as a base for the regulation. Should the **valve regression be greater than 2,5 mm**, GE Jenbacher will offer an exchange taking into account aliquot offsetting of the **material price** (labour costs excluded).

Up to 5000 operating hours the head is replaced free of charge. From 5000 operating hours an aliquot calculation is used according to the following list:

Customer's participation	
(material only)	
Bh	
from 5.000	25%
from 6.000	30%
from 7.000	35%
from 8.000	40%
from 9.000	45%
from 10.000	50%
from 11.000	55%
from 12.000	60%
from 13.000	65%
from 14.000	70%
from 15.000	75%
from 16.000	80%
from 17.000	85%
from 18.000	90%
from 19.000	95%
from 20.000	100%



This regulation is subject to withdrawal.



Eugen Laner
 Service Director
 GE Jenbacher