



GE Energy

Thomas Hofer

Verteiler: Jenbacher Service
Subsidiaries Service
Service Partner

GE Jenbacher GmbH & Co OHG
Achenseestr. 1-3
A-6200 Jenbach, Austria

T +435244 600-2720
thomas.hofer@ge.com

Service Technician Instruction ST – 033 29. November 2005

Limit value for knock monitoring system type 3 version C

The default parameters regarding knock limit KLS 90 for type 3 version C are changed from 4.5 mA to 5 mA. This adaptation is founded on design changes of the cylinder head.

Because of a possible interference a minimum distance of 3 cm between the high voltage cable of the ignition system with o-coil and cable of the knocking sensor is necessary.

The modification is based on the research and development report 04/927.